

Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.cityofhouston.gov

May 1, 2006

Land Assemblage Redevelopment Authority 2314 Carr Street Houston, Texas 77026 HCAD #0091460000004

Re: Wastewater and Water Reservation No. 0028967-000 Lot #2570 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,450 square feet of land being Lot 4, Block 26, Chapmans, Section 2, located at 2314 Carr Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 12-inch sewer in Carr Street.*

Water connection must be made to the 8-inch water main in Carr Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Bill White

Public Works and Engineering Department

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.cityofhouston.gov

May 1, 2006

Land Assemblage Redevelopment Authority 2602 Chew Street Houston, Texas 77020 HCAD #0092570000007

Re: Wastewater and Water Reservation No. 0028968-000 Lot # 2582 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 7, Block 23, F. F. Chew, located at 2602 Chew Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Chew or in Downing.*

Water connection must be made to the 8-inch water main in Chew or to the 6-inch water main in Downing.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Cordially

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Department

Public Works and Engineering

Mayor

Bill White

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.cityofhouston.gov

May 1, 2006

Land Assemblage Redevelopment Authority 5707 Colfax Street Houston, Texas 77020 HCAD #0092480000004

Re: Wastewater and Water Reservation No. 0028969-000 Lot #5520 Fifth Wood

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 10,000 square feet of land being Lots 4 and 5, Block 14, F. F. Chew, located at 5707 Colfax Street.

Wastewater and water capacity is currently available for your proposed construction of two (2) single family residences, or a development utilizing a maximum of 2.0 service units per day.

An Impact Fee in the amount of \$2,134.94 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$601.86 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Sakowitz.*

Water connection must be made to the 12-inch water main in Sakowitz.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.cityofhouston.gov

May 1, 2006

Land Assemblage Redevelopment Authority 4006 Eddie Street Houston, Texas 77026 HCAD #0561330000009

Re: Wastewater and Water Reservation No. 0028970-000 Lot # 2578 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 9, Block 3, Comfort Place, located at 4006 Eddie Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Eddie Street.*

Water connection must be made to the 8-inch water main in Eddie Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 4018 Eddie Street Houston, Texas 77026 HCAD #0561330000006

Re: Wastewater and Water Reservation No. 0028971-000 Lot # 2577 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 6,500 square feet of land being Lot 6, Block 3, Comfort Place, located at 4018 Eddie Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Eddie Street.*

Water connection must be made to the 8-inch water main in Eddie Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 4501 Evella Street
Houston, Texas 77026
HCAD # 0040350000009

Re: Wastewater and Water Reservation No. 0029009-000 Lot # 2587 Fifth Wand

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 10,000 square feet of land being Lots and 10, Block 29, Augusta, located at 4501 Evella Street.

Wastewater and water capacity is currently available for your proposed construction of a single residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 6-inch sewer in Evella Street or in Amboy Street.*

Water connection must be made to the 6-inch water main in Eyella Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Morene, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

MSM:RM:fs W2006042983

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Mayor

Bill White

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 3207 Farmer Street Houston, Texas 77020 HCAD # 0211390000032

Re: Wastewater and Water Reservation No. 0029010-000 Lot # 5532 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 4,450 square feet of land being Tract 25, Block 1, Ingraham, located at 3207 Farmer Street.

Wastewater and water capacity is currently available for your proposed construction of one (1) single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 12-inch sewer in Farmer.*

Water connection must be made to the 2-inch water main in Farmer. The maximum allowable for a 2-inch is a 1-inch.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

MSM:RM:eg W2006043084

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

May 1, 2006

Land Assemblage Redevelopment Authority 3313 Farmer Street Houston, Texas 77020 HCAD #0211440060003

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

Re: Wastewater and Water Reservation No. 0028972-000 Lot # 5535 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 7,5000 square feet of land being Lot 16 and Tract 3, Block 6, Ingraham, located at 3313 Farmer Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 12-inch sewer in Farmer Street.*

Water connection must be made to the 2-inch water main in Farmer Street. The maximum allowable meter for a 2-inch line is 1-inch.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 0 Jewel Houston, Texas 77026 HCAD #0701040010016

Re: Wastewater and Water Reservation No. 0028973-000 Lat # 5534 Fifth Wand

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 16, Block 1, Colonia Weisenberger, located on Jewel.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Jewel.*

Water connection must be made to the 8-inch water main in Jewel.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 4015 Jewel Street
Houston, Texas 77026
HCAD # 0701040020003

Re: Wastewater and Water Reservation No. 0029037-000 Lot # 2573 Fifth Wand

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,049 square feet of land being Lot 3, Block 2, Colonia Weisenberger, located at 4015 Jewel Street.

Wastewater and water capacity is currently available for your proposed construction of one (1) single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Jewel Street.*

Water connection must be made to the 8-inch water main in Jewel Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

MSM:RM:fs W2006043012

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 0 Kirk
Houston, Texas 77026
HCAD #0503460000065

Re: Wastewater and Water Reservation No. 0028974-000 Lot # 2663 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 4,800 square feet of land being Lot 65, Liberty, located at Kirk.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Kirk.*

Water connection must be made to the 20-inch water main in Kirk.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Morend, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 2319 Leffingwell Street Houston, Texas 77026 HCAD #0170680000011

Re: Wastewater and Water Reservation No. 0028975-000 Lot # 2665 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land of being Lot 11, Block 17, Home, located at 2319 Leffingwell Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in the easement.*

NO CONSTRUCTION (SLAB OR STRUCTURE) WILL BE PERMITTED WITHIN FIVE (5') FEET OF THIS LINE.

Water connection must be made to the 8-inch water main in Leffingwell Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Morend Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 2323 Leffingwell Street Houston, Texas 77026 HCAD #0170680000012

Re: Wastewater and Water Reservation No. 0028976-000 Lot #2672 Fifth word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 12, Block 17, Home, located at 2323 Leffingwell Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 6-inch sewer in the easement.*

NO CONSTRUCTION (SLAB OR STRUCTURE) WILL BE PERMITTED WITHIN FIVE (5') FEET OF THIS LINE.

Water connection must be made to the 8-inch water main in Leffingwell Street or in Quitman.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Ir., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 4037 Lelia Street Houston, Texas 77026 HCAD #0561440000010

Re: Wastewater and Water Reservation No. 0028977-000 Lot #5518 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 10, Block 14, Comfort Place, located at 4037 Lelia Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Lelia Street.*

Water connection must be made to the 8-inch water main in Lelia Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 4401 Liberty Road Houston, Texas 77026 HCAD #0393480000010

Re: Wastewater and Water Reservation No. 0028978-000 Lot # 2664 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 7,448 square feet of land being Lot 10, Block 8, Grant Park, located at 4401 Liberty Road.

Wastewater and water capacity is currently available for your proposed construction of three (3) single family residences, or a development utilizing a maximum of 3.0 service units per day.

An Impact Fee in the amount of \$3,202.41 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$902.79 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 92-inch or the 8-inch sewer in Wayne.*

Water connection must be made to the 8-inch water main in Liberty Road.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 0 Lucille Street Houston, Texas 77026 HCAD #0300190010005

Re: Wastewater and Water Reservation No. 0028979-000 Lat # 3658 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 4,500 square feet of land being Lot 5, Block 1, Ralston, located on Lucille Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Lucille Street.*

Water connection must be made to the 8-inch water main in Lucille Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 0 Lucille Houston, Texas 77026 HCAD #0402660090062

Re: Wastewater and Water Reservation No. 0028980-000 Lot # 2591 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 62, Liberty Gardens, Section 4, located on Lucille Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 6-inch sewer in Lucille Street.*

Water connection must be made to the 4-inch water main in Lucille Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 0 Lucille Houston, Texas 77026 HCAD #0561440000019

Re: Wastewater and Water Reservation No. 0028981-000 Let # abol Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 19, Block 14, Comfort Place, located on Lucille Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Lucille Street.*

Water connection must be made to the 8-inch water main in Lucille Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P. O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: M

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Mayor

Bill White

May 1, 2006

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

Land Assemblage Redevelopment Authority 3706 Lucille Street Houston, Texas 77026 HCAD #0300190010002

Re: Wastewater and Water Reservation No. 0028982-000 Let # 2660 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 4,500 square feet of land being Lot 2, Block 1, Ralston, located at 3706 Lucille Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the abovequoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Lucille Street.*

Water connection must be made to the 8-inch water main in Lucille Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 3710 Lucille Street Houston Texas 77026 HCAD #0300190010003

Re: Wastewater and Water Reservation No. 0028983-000 Lot # 2659 Fifth Wand

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 4,500 square feet of land being Lot 3, Block 1, located at 3710 Lucille Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Lucille Street.*

Water connection must be made to the 8-inch water main in Lucille Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

May 1, 2006

Land Assemblage Redevelopment Authority 4009 Lucille Street Houston, Texas 77026-5735 HCAD # 0701040010002 **Bill White**

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

Re: Wastewater and Water Reservation No. 0028984-000 Lot # 2576 Fifth World

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 2, Block 1, Colonia Weisenberger, located at 4009 Lucille Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Lucille Street.*

Water connection must be made to the 8-inch water main in Lucille Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, J. E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Mayor

Public Works and Engineering Department

iviayoi

Bill White

May 1, 2006

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

Land Assemblage Redevelopment Authority 0 Noble Street Houston, Texas 77026 HCAD # 0151990000010

Re: Wastewater and Water Reservation No. 0028985-000 Lot # 2668 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 6,175 square feet of land being Tracts 3 and 4, Block 9, Greggs, Section 2, located on Noble Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Noble Street.*

Water connection must be made to the 8-inch water main in Noble Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Cordially,

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

May 1, 2006

Land Assemblage Redevelopment Authority 2610 Russell Street Houston, Texas 77026 HCAD #0561330000010 **Bill White**

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

Re: Wastewater and Water Reservation No. 0029001-000 Lat # 2579 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land, being Lot 10, Block 3, Comfort Place, located at 2610 Russell Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Russell Street or in Eddie Street.*

Water connection must be made to the 8-inch water main in Eddie Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Morego, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Department

Public Works and Engineering

N

Mayor

Bill White

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927

www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 0 Sakowitz Street Houston, Texas 77020 HCAD #0092470000001

Re: Wastewater and Water Reservation No. 0029002-000 Lot # 5521 Fifth Ward Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 1, Block 13, F. F. Chew, located on Sakowitz Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 6-inch sewer in Sakowitz Street.*

Water connection must be made to the 12-inch water main in Sakowitz Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

. .

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 0 Sakowitz Street Houston, Texas 77020 HCAD #0092410000002

Re: Wastewater and Water Reservation No. 0029003-000 Lot # 2662 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 2, Block 7, F. F. Chew, located on Sakowitz.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Sakowitz Street.*

Water connection must be made to the 12-inch water main in Sakowitz Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 2111 Sakowitz Street Houston, Texas 77020 HCAD #0092350000002

Re: Wastewater and Water Reservation No. 0029054-000 Lot # 2585 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 acre of land being Lot 2, Block 1, F. F. Chew, located at 2111 Sakowitz Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Failure to pay the Impact Fees within six (6) months from the date of this letter will result in the expiration of this reservation. The Impact Fees may be paid by mail or at 3300 Main, First Floor. A copy of the Impact Fee receipts and a copy of this letter must be submitted with your construction

plans when applying for a building permit. Please note, the Wastewater and Water Impact Fees quoted above are not refundable for any reason including failure to obtain a building permit or failure to proceed with the project for any reason.

Sanitary sewer connection must be made to the 8-inch sewer in Sakowitz Street.*

Water connection must be made to the 12-inch or to the 6-inch water main in Nichols.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Møreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

May 1, 2006

Land Assemblage Redevelopment Authority 2607 Sakowitz Street Houston, Texas 77020 HCAD #0092580000005 **Bill White**

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

Re: Wastewater and Water Reservation No. 0029004-000 Lot # 2586 Fifth Wood

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 10,000 square feet of land being Lots 5 and 6, Block 24, F. F. Chew, located at 2607 Sakowitz Street.

Wastewater and water capacity is currently available for your proposed construction of two (2) single family residences or a development utilizing a maximum of 2.0 service units per day.

An Impact Fee in the amount of \$2,134.94 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$601.86 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Sakowitz Street.*

Water connection must be made to the 12-inch water main in Sakowitz Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For: Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Mayor

Bill White

Public Works and Engineering Department

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927

www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 2110 Sam Wilson Street Houston, Texas 77020 HCAD #0092350000010

Re: Wastewater and Water Reservation No. 0029005-000 Lot #5500 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 5,000 square feet of land being Lot 10, Block 1, F. F. Chew, located at 2110 Sam Wilson Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Sam Wilson Street*

Water connection must be made to the 8-inch water main in Sam Wilson Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Morepo, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 2208 Sam Wilson Street Houston, Texas 77020 HCAD # 0092410000006

Re: Wastewater and Water Reservation No. 0029006-000 Lot # 2584 Fifth Ward

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 10,000 square feet of land being Lots 6 and 7, Block 7, F. F. Chew, located at 2208 Sam Wilson Street.

Wastewater and water capacity is currently available for your proposed construction of two (2) single family residences, or a development utilizing a maximum of 2.0 service units per day.

An Impact Fee in the amount of \$2,134.94 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$601.86 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Sam Wilson Street.*

Water connection must be made to the 8-inch water main in Sam Wilson Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

MSM:RM:fs W2006042980

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Public Works and Engineering Department

Bill White

Mayor

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 2422 Sam Wilson Street Houston, Texas 77020 HCAD # 0092480000006

Re: Wastewater and Water Reservation No. 0029007-000 Let # 2583 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 10,000 square feet of land being Lots 6 and 7, Block 14, F. F. Chew, located at 2422 Sam Wilson Street.

Wastewater and water capacity is currently available for your proposed construction of two (2) single family residences, or a development utilizing a maximum of 2.0 service units per day.

An Impact Fee in the amount of \$2,134.94 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$601.86 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 8-inch sewer in Sam Wilson Street.*

Water connection must be made to the 8-inch water main in Sam Wilson Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Morego, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

MSM:RM:fs W2006042981

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.



Mayor

Bill White

Public Works and Engineering Department

Michael S. Marcotte, P.E., DEE Director Public Works & Engineering Department P.O. Box 131927 Houston, Texas 77219-1927 www.houstontx.gov

May 1, 2006

Land Assemblage Redevelopment Authority 0 West Street Houston, Texas 77026 HCAD # 0151990000009

Re: Wastewater and Water Reservation No. 0029008-000 Lot # 2069 Fifth Word

Dear Applicant:

Reference is made to your application concerning the availability of water and wastewater capacity to 6,250 square feet being Tracts 1A, 2A and 3A, Greggs, Section 2, located on West Street.

Wastewater and water capacity is currently available for your proposed construction of a single family residence, or a development utilizing a maximum of 1.0 service unit per day.

An Impact Fee in the amount of \$1,067.47 and a \$5.00 Administrative Fee must be paid in order to reserve wastewater capacity. An Impact Fee in the amount of \$300.93 and a \$5.00 Administrative Fee must be paid in order to reserve water capacity. These fees must be paid within six (6) months from the date of this letter and prior to the issuance of a building permit. Houston City Council may review and revise related ordinances, which will change the above-quoted fees and/or the development criteria and design requirements for this project.

Ordinances provide for a waiver of impact fees for houses (single-family residences) that sell to the first-time purchaser for less than the median price of a home in Houston during the month the proposed home is permitted. Currently, the median price is approximately \$142,050. If you feel that your proposed development may qualify for this exemption, please do not pay the impact fees referenced in this letter and make certain that you fill out an Impact Fee Exemption Form at 3300 Main when applying for a building permit.

Furthermore, the City Engineer may, from time to time, revise the Department of Public Works Infrastructure Design Manual, resulting in changes to the design criteria and parameters that must be followed in the development of this site.

Sanitary sewer connection must be made to the 10-inch sewer in West Street.*

Water connection must be made to the 8-inch water main in West Street.*

Please note, fill exceeding one (1) foot in height above natural grade requires a grading permit in compliance with Appendix E, 2000 International Building Code, unless exempted by Section E103.2.

If this project is not under construction within two (2) years from the date of this letter, the water and storm drainage portion of this reservation will expire, and a renewal request must be submitted.

For any written inquiries regarding the above information please contact:

The Utility Analysis Section P.O. Box 131927 Houston, Texas 77219-1927

Questions or comments concerning this letter can be faxed to (713) 837-0149. For direct inquiries concerning the water portion of this letter, please contact Ms. Christine Robinson at (713) 837-0136, or contact me at (713) 837-0137. You may also email questions to wcrtechs@cityofhouston.net.

Cordially,

Rudy Moreno, Jr., E.I.T.

Division Manager

Utility Analysis Section

For:

Michael S. Marcotte, P.E., DEE

Director

Department of Public Works and Engineering

MSM:RM:fs W2006042982

^{*}This information is based on the City of Houston Geographic Information Management System maps. These maps are prepared utilizing the best information available to the City and the City cannot warrant their accuracy or completeness. The exact size and location of all utility lines should be field verified.